

# 2025 Annual Drinking Water Quality Report

## Town Of Oak Island

Water System Number: NC04-10-020  
Sample Period from 1-1-2025 thru 12-31-2025

We are pleased to present to you this year's Annual Drinking Water Quality Report. This report is a snapshot of last year's water quality. Included are details about your source(s) of water, what it contains, and how it compares to standards set by regulatory agencies. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water and to providing you with this information because informed customers are our best allies. **If you have any questions about this report or concerning your water, please contact Tray Bivins at 910-201-8007. We want our valued customers to be informed about their water utility. If you want to learn more, please attend any of our regularly scheduled meetings. They are being held at Oak Island Town Hall, 4601 E. Oak Island DR. the second Tuesday of each month at 6:00pm. To view this report online visit <http://oakislandNC.gov/WaterReport>**

### What EPA Wants You to Know

Drinking water, including bottled water, may reasonably be expected to contain at least some small amounts of contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline (800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, people who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity. Contaminants that may be present in source water include:

Microbial Contaminants: such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife

Inorganic Contaminants: such as salts and metals, which can be naturally occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming

Pesticides and Herbicides: which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses

Organic Chemical Contaminants: including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems

Radioactive Contaminants: which can naturally occur or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the number of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water, which must provide the same protection for public health.

## Lead in Drinking Water

Lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Town of Oak Island is responsible for providing high quality drinking water and removing lead pipes but cannot control the variety of materials used in plumbing components in your home. You share the responsibility for protecting yourself and your family from the lead in your home plumbing. You can take responsibility by identifying and removing lead materials within your home plumbing and taking steps to reduce your family's risk. Before drinking tap water, flush your pipes for several minutes by running your tap, taking a shower, doing laundry or a load of dishes. You can also use a filter certified by an American National Standards Institute accredited certifier to reduce lead in drinking water. If you are concerned about lead in your water and wish to have your water tested, contact **Tray Bivins** at [tbivins@oakislandnc.gov](mailto:tbivins@oakislandnc.gov) Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available at <http://www.epa.gov/safewater/lead>

We have been working to identify service line materials throughout the water system and prepared an inventory of all service lines in our water system. To access this inventory, Email [shaas@oakislandnc.gov](mailto:shaas@oakislandnc.gov)

## When You Turn on Your Tap, Consider the Source

The water that is used by this system is purchased from Brunswick County. Brunswick county operates two water treatment plants, the Northwest WTP is a 24 million gallon per day surface water treatment plant that takes water from the cape fear river above lock and dam #1 in Bladen County and the highway 211 WTP is a 6 MGD ground water treatment plant which treats ground water from the Castle Hayne aquifer,14 wells approximately 175 feet deep. Drinking water is blended from Northwest WTP and the 211 WTP to serve customers.

This system purchases water from Brunswick County (NC-04-10045). View Brunswick County's CCR at <https://www.brunswickcountync.gov/DocumentCenter/View/7367/Consumer-Confidence-Report-CCR-2025>

## Source Water Assessment Program (SWAP) Results

The North Carolina Department of Environmental Quality (DEQ), Public Water Supply (PWS) Section, Source Water Assessment Program (SWAP) conducted assessments for all drinking water sources across North Carolina. The purpose of the assessments was to determine the susceptibility of each drinking water source (well or surface water intake) to Potential Contaminant Sources (PCSs). The results of the assessment are available in SWAP Assessment Reports that include maps, background information and a relative susceptibility rating of Higher, Moderate or Lower.

The relative susceptibility rating of each source for Brunswick County was determined by combining the contaminant rating (number and location of PCSs within the assessment area) and the inherent vulnerability rating (i.e., characteristics or existing conditions of the well or watershed and its delineated assessment area). The assessment findings are summarized in the table below:

Source Name	Susceptibility Rating	SWAP Report Date
Cape Fear River	MODERATE	September 2020
Well # 1,2,15,16,17	LOW	September 2020
Well # 3,8,11,12,12A,18,19	MODERATE	September 2020
Well # 5,6A	HIGHER	September 2020

The complete SWAP Assessment report for Brunswick County Water System may be viewed on the Web at: <https://www.ncwater.org/?page=600> then enter 0410045. Note that because SWAP results and reports are periodically updated by the PWS Section, the results available on this website may differ from the results that were available at the time this CCR was prepared. If you are unable to access your SWAP report on the web, you may mail a written request for a printed copy to: Source Water Assessment Program – Report Request, 1634 Mail Service Center, Raleigh, NC 27699-1634, or email requests to [swap@deq.nc.gov](mailto:swap@deq.nc.gov). Please indicate your system name, number, and provide your name,

mailing address and phone number. If you have any questions about the SWAP report, please contact the Source Water Assessment staff by phone at (919) 707-9098.

It is important to understand that a susceptibility rating of “higher” does not imply poor water quality, only the system’s potential to become contaminated by PCSs in the assessment area.

## **Help Protect Your Source Water**

Protection of drinking water is everyone’s responsibility. We have implemented the following source water protection actions: You can help protect your community’s drinking water source(s) in several ways: (examples: dispose of chemicals properly; take used motor oil to a recycling center, watering your lawn in the morning saves water from being evaporated by the midday heat and reduces your water bill. Peak demand for water is between 5:00 am and 7:00 pm. If irrigation is necessary, irrigate during off peak times. Installing a water-efficient showerhead can reduce water consumption by 25% to 60% and save energy. Check your toilet by using a leak detection dye tab, otherwise you could be wasting about 200 gallons of water a day. Washing only full loads of laundry can save an average household more than 3,400 gallons of water each year. volunteer in your community to participate in group efforts to protect your source, etc.).

## **Violations that Your Water System Received for the Report Year**

**The Town of Oak Island is Proud to Announce No Violations in 2025**

### Distribution System

The Public Utilities Maintenance Department would like to let you know that we are here to serve you with any of your utility needs 24 hours a day. If you plan to dig and are not sure who to call, we can help. We have all the numbers you will need to contact any other utilities for locates. If you have any water quality issues or feel that your water meter is not working, please contact our office at (910) 210-8007 we will be glad to work with you to solve any water issues.

## **Important Drinking Water Definitions:**

**Action Level (AL)** - The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

**Maximum Contaminant Level (MCL)** - The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

**Maximum Contaminant Level Goal (MCLG)** - The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

**Parts per million (ppm) or Milligrams per liter (mg/L)** - One part per million corresponds to one minute in two years or a single penny in \$10,000.

**Parts per billion (ppb) or Micrograms per liter (ug/L)** - One part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

---

**Locational Running Annual Average (LRAA)** – The average of sample analytical results for samples taken at a particular monitoring location during the previous four calendar quarters under the Stage 2 Disinfectants and Disinfection Byproducts Rule.

**Maximum Residual Disinfection Level (MRDL)** – The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

**Maximum Residual Disinfection Level Goal (MRDLG)** – The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminant.

**Not-Applicable (N/A)** – Information not applicable/not required for that particular water system or for that particular rule.

**Non-Detects (ND)** - Laboratory analysis indicates that the contaminant is not present at the level of detection set for the particular methodology used.

**Running Annual Average (RAA)** – The average of sample analytical results for samples taken during the previous four calendar quarters.

**Treatment Technique (TT)** - A required process intended to reduce the level of a contaminant in drinking water.

**Variations and Exceptions** – State or EPA permission not to meet an MCL or Treatment Technique under certain conditions.

## Water Quality Data Tables of Detected Contaminants

We routinely monitor for over 150 contaminants in your drinking water according to Federal and State laws. The tables below list all the drinking water contaminants that we detected in the last round of sampling for each particular contaminant group. The presence of contaminants does not necessarily indicate that water poses a health risk. **Unless otherwise noted, the data presented in this table is from testing done January 1 through December 31, 2025.** The EPA and the State allow us to monitor certain contaminants less than once per year because the concentrations of these contaminants are not expected to vary significantly from year to year. Some of the data, though representative of the water quality, is more than one year old.

### Lead and Copper Contaminants

The table summarizes our most recent lead and copper tap sampling data. If you would like to review the complete lead tap sampling data, please email us at <a href="mailto:tbivins@oakislandnc.gov">tbivins@oakislandnc.gov</a> .								
Contaminant (units)	Sample Date	Your Water (90 <sup>th</sup> Percentile)	Number of sites found above the AL	Range		MCLG	AL	Likely Source of Contamination
				Low	High			
Copper (ppm) (90 <sup>th</sup> percentile)	6-20-2023	.206	0	.000	.264	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits
Lead (ppb) (90 <sup>th</sup> percentile)	6-20-2023	.000	0	.000	.000	0	AL=15	Corrosion of household plumbing systems; erosion of natural deposits
The table above summarizes our most recent lead and copper tap sampling data. If you would like to review the complete lead tap sampling data, please email us at <a href="mailto:Tbivins@oakislandnc.gov">Tbivins@oakislandnc.gov</a>								
We have been working to identify service line materials throughout the water system and prepared an inventory of all service lines in our water system. To access this inventory, Contact <a href="mailto:Shaas@oakislandnc.gov">Shaas@oakislandnc.gov</a>								
Lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Town of oak Island is responsible for providing high quality drinking water and removing lead pipes but cannot control the variety of materials used in plumbing components in your home. You share the responsibility for protecting yourself and your family from the lead in your home plumbing. You can take responsibility by identifying and removing lead materials within your home plumbing and taking steps to reduce your family's risk. Before drinking tap water, flush your pipes for several minutes by running your tap, taking a shower, doing laundry or a load of dishes. You can also use a filter certified by an American National Standards Institute accredited certifier to reduce lead in drinking water. If you are concerned about lead in your water and wish to have your water tested, contact Town of oak island <a href="mailto:Tbivins@oakislandnc.gov">Tbivins@oakislandnc.gov</a> Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available at <a href="http://www.epa.gov/safewater/lead">http://www.epa.gov/safewater/lead</a>								

### Stage 2 Disinfection Byproducts (DBPs) Total Trihalomethanes (TTHM) and Haloacetic Acids (five) (HAA5)

Disinfection Byproduct	Year Sampled	MCL Violation Y/N	Your Water	Range		MCLG	MCL	Likely Source of Contamination
				Low	High			
TTHM (ppb)	2025	N	16	8	29	N/A	80	Byproduct of drinking water disinfection
HAA5 (ppb)	2025	N	15	7	24	N/A	60	Byproduct of drinking water disinfection

**Disinfectant Residuals Summary**

	MRDL Violation Y/N	Your Water (RAA)	Range		MRDLG	MRDL	Likely Source of Contamination
			Low	High			
Chlorine (ppm)	N	.27	0	1.75	4	4.0	Water additive used to control microbes
Chloramines (ppm)	N	1.45	0	3.63	4	4.0	Water additive used to control microbes

**Asbestos Contaminant**

Contaminant (units)	Sample Date	MCL Violation Y/N	Your Water	Range		MCLG	MCL	Likely Source of Contamination
				Low	High			
Total Asbestos (MFL)	6-17- 2020	N	0	N/A		7	7	Decay of asbestos cement water mains; erosion of natural deposits

**Unregulated Contaminants Monitoring Regulation (UCMR)**

Contaminant (units)	Sample Date	Your Water (average)	Range	
			Low	High
PFBS	7-2024	.0017	.0	.0052
PFHPA	7-2024	.0012	.0	.0036
PFHZA	7-2024	.0026	.0	.0079

Our water system has sampled for a series of unregulated contaminants. Unregulated contaminants are those for which EPA has not established drinking water standards. The purpose of unregulated contaminant monitoring is to assist EPA in determining the occurrence of unregulated contaminants in drinking water and whether future regulations are warranted. If you are interested in examining the results, please contact us at [tbivins@oakislandnc.gov](mailto:tbivins@oakislandnc.gov)